

**PROCEDURE 13 - Indoor Air Quality**

<u>Table of Contents</u>	<u>Page</u>
Synopsis .....	13-ii
Indoor Air Quality Checklist.....	13-iii
13 INDOOR AIR QUALITY.....	13-4
13.1 Purpose and Scope .....	13-4
13.2 Definitions.....	13-4
13.3 Procedure .....	13-4
13.4 Responsibilities .....	13-6
13.5 References .....	13-7
13.6 Attachments .....	13-7

## **Synopsis**

This procedure identifies health hazards associated with poor indoor air quality and provide guidelines to reduce potential exposure to these hazards. This procedure applies to all NWS facilities, work locations, and employees.

### **Initial Implementation Requirements:**

- **Analyze Site Operations versus Requirements of the Procedure**
  - Perform Indoor Air Quality Investigation to address employees' complaints (if applicable). (13.3.8)
- **Develop/Obtain/Provide Documentation/Information required for Site**
  - Inform personnel about painting, renovations and other activities that may affect the Air Quality (13.3.If.3)
- **Designate Person to Administer the Indoor Air Quality Procedure Requirements**
- **Provide Local Training of Site Personnel (if applicable)**
- **Designate Person for Contractor Oversight (If applicable)**
- **Inventory Material/Equipment (Procure as required)**
  - HVAC filters (13.3.7)

### **Recurring and Annual Task Requirements:**

- **Perform Inspection/Assessment**
  - Maintain HVAC systems per established preventive maintenance schedule (13.3.3)
- **Review/Update Documentation**
  - Maintain records of indoor air quality complaints, investigations, and corrective actions (13.3.8)
- **Provide Refresher Training of Site Personnel (As required)**
- **Inspect/Replace/Recalibrate Maintain Material/Equipment**
  - HVAC filters (13.3.7)

**Indoor Air Quality Checklist**

<b>Requirements</b>	<b>Reference</b>	<b>YES</b>	<b>NO</b>	<b>N/A</b>	<b>Comments</b>
Are initial and annual reviews of this procedure conducted and documented?	13.4.2				
Is facility's Heating, Ventilation and Air Conditioning (HVAC) system being checked semi-annually as recommended by this procedure?	13.3.3				
Has the facility established a preventative maintenance schedule for the HVAC system?	13.3.3				
Is the facility free of areas of microbial growth, particularly the HVAC drip pans, drop ceiling panels, carpeting, etc.?	13.3.4				
Is the relative humidity maintained between 30% and 60% in the facility?	13.3.4				
Are HVAC systems designed to properly distribute air throughout the workspace?	13.3.5				
Are HVAC air intakes located to minimize the entrance of contaminants into the workplace (from sources such as industrial areas or parking lots)?	13.3.6				
Are all HVAC drip pans equipped with gravity drains?	13.3.4				
Have all indoor air quality concerns been investigated and documented?	13.3.8				

## **13 INDOOR AIR QUALITY**

### **13.1 Purpose and Scope**

As part of its goal to provide a safe and healthful workplace, the National Weather Service (NWS) is implementing this procedure related to hazards associated with poor indoor air quality. This procedure applies to all NWS facilities, work locations, and employees.

### **13.2 Definitions**

ACGIH. American Conference of Governmental Industrial Hygienists.

ASHRAE. American Society of Heating, Refrigeration, and Air Conditioning Engineers.

CFR. Code of Federal Regulations.

Field Office. A Field Office may include the following: Weather Forecast Office (WFO), River Forecast Center (RFC), Weather Service Office (WSO), and a Data Collection Office (DCO).

EPA. United States Environmental Protection Agency.

Operating Unit. For the purpose of this procedure, Operating Unit includes the National Centers for Environmental Prediction (NCEP), National Data Buoy Center (NDBC), NWS Training Center (NWSTC), National Reconditioning Center (NRC), Radar Operations Center (ROC), or the Sterling Field Support Center (SFSC).

OSHA. Occupational Safety and Health Administration.

Station Manager. For the purpose of this procedure, the Station Manager shall be either the NWS Regional Director; Directors of Centers under NCEP (Aviation Weather Center, NP6; Storm Prediction Center, NP7; and Tropical Prediction Center, NP8; Space Weather Prediction Center, NP9); Directors of the NDBC, NWSTC, and Chiefs of NRC, ROC and SR&DC facilities; or Meteorologist in Charge (MIC), Hydrologist in Charge (HIC), or Official in Charge (OIC).

### **13.3 Procedure**

13.3.1 New facility Heating, Ventilation and Air Conditioning (HVAC) systems for NWS facilities shall be designed to comply with ASHRAE 62, "Ventilation for Acceptable Indoor Quality" and ASHRAE Standard 55, "Thermal Environmental Conditions for Human Occupancy." In particular, the volume of outside fresh air supplied to the workplace shall comply with the most recent version of ASHRAE 62.

13.3.2 Existing facility HVAC systems at NWS facilities shall comply with ASHRAE 62 to the maximum extent feasible.

13.3.3 Facilities personnel shall perform periodic checks on HVAC system performance. These checks should coincide with the facility's established preventative maintenance schedule. A semi-annual schedule is recommended.

13.3.4 Any areas where microbial growth is noted shall be properly sanitized, particularly in areas where spores and mold may be introduced into the workplace air. A relative humidity

between 30 and 60 percent is generally recommended to minimize microbial growth. All drip pans located in ductwork should have gravity drains. Care shall be taken to ensure that condensate does not accumulate in ductwork and that drains are kept clean.

13.3.5 HVAC systems shall be designed so that air is properly distributed throughout the workplace. During design or remodeling of office spaces, care shall be given to the correct placement of supply and return air ducts and diffusers. Office partitions shall be located in positions which will not disrupt correct airflow.

13.3.6 HVAC air intakes shall be located within a facility to minimize intake of contaminants from parking lots, exhaust stacks, adjacent highways or other sources of contaminants.

13.3.7 HVAC systems shall be maintained per manufacturer’s recommendations, including periodic inspection and changing of filters. Adequate stock of filters shall be maintained, as required.

13.3.8 The Station Manager shall contact the NWS Regional Environmental/Safety Coordinator to obtain assistance in evaluating and addressing employees’ complaints or concerns related to indoor air quality. The EPA document “Building Air Quality: A Guide for Building Owners and Facility Managers” provides guidelines for performing Indoor Air Quality investigations. Facility personnel may be incorporated into the investigation if warranted. Investigations results shall be documented and maintained along with corrective actions which were implemented.

13.3.9 No employee shall be exposed to any regulated contaminant in excess of OSHA permissible exposure limits or ACGIH threshold limit values. The table 13-1, “Common Indoor Air Contaminants,” lists a few of the common contaminants found in the indoor environment. The exposure limits are listed in terms of milligrams per cubic meter (mg/m<sup>3</sup>) or parts per million (ppm). Although OSHA and EPA do not have specific exposure limits for indoor air quality, the EPA recommends offices should not exceed 10% of industrial health exposure limits.

**Table 13-1. COMMON INDOOR AIR CONTAMINANTS**

CONTAMINANT	OSHA PEL, 8 HOUR TWA	ACGIH TLV, 8 HOUR TWA	OTHER GUIDELINES
Carbon Monoxide	50 ppm	25 ppm	11 ppm - World Health Organization
Formaldehyde	0.72 ppm	0.3 ppm	N/A
Total Particulate	15 mg/m <sup>3</sup>	10 mg/m <sup>3</sup>	75 ug/m <sup>3</sup> - EPA Ambient Air Standard
Total Respirable Particulate	5 mg/m <sup>3</sup>	3 mg/m <sup>3</sup>	N/A
Carbon Dioxide	5000 ppm	5000 ppm	1000 ppm - ASHRAE 62

13.3.10 ASHRAE recommends a temperature range of 73°-79° F in summer conditions and a range of 68°-73° F in winter to maximize thermal comfort in office environments.

13.3.11 Miscellaneous. The complexity of studying and measuring the quality of office environment arises from various factors including:

- a. Office building floor plans are frequently changing to accommodate increasingly more employees and organization.
- b. Office buildings frequently undergo building renovations such as installation of new carpet, modular office partitions and freestanding offices, and painting.
- c. Many of the health symptoms appearing are vague and common both to the office and home environment.
- d. In general, very little data on pollutant levels within office environments is available.
- e. Guidelines or standards for permissible personal exposure limits to pollutants within office building are very limited.
- f. Ensure custodial employees are cleaning horizontal surfaces on the regular schedule (once a week is recommended).
- g. Frequently odors associated with chemical contaminants are noticeable following a building's renovation or installation of new carpeting. Vapors from paints, adhesives, sealants, office furniture, carpeting, and vinyl wall coverings are the source of a variety of irritant compounds. Although there is often no immediate danger to employees' safety and health (unless an employee has a known allergic reaction), measures shall be taken to minimize the discomforts associated with the irritating vapors. Among the measures to be employed are:
  - (1) Schedule carpeting, painting and other renovation activities for the weekends or after regular hours, whenever possible.
  - (2) Ventilate the affected area as much as possible to diminish concentration of the chemicals in the air as well as odors associated with the vaporized chemicals.
  - (3) Inform personnel regarding upcoming renovation activities that may cause irritating vapors to occur. This measure will allow time to arrange a temporary move of individual(s) with known allergy problems to another work area.

## **13.4 Responsibilities**

### **13.4.1 Regional or Operating Unit Environmental/Safety Coordinators**

- a. Will monitor and promote compliance with the requirements of this procedure at field offices or Operating Unit facilities.
- b. Will ensure that applicable procedures are implemented at regional headquarters or Operating Unit facilities.

### **13.4.2 Station Manager**

- a. Will review or delegate review, of this procedure on an annual basis to ensure that the facility is complying with its requirements. Confirmation of this review shall be forwarded to the Regional or Operating Unit Environmental/Safety Coordinator.

- b. Will have oversight over the implementation of this procedure, and ensure that the requirements of this procedure are followed by individuals at the NWS facility.

#### 13.4.3 NWS Headquarters (NWSH)

- a. The NWS Safety Office will provide assistance to Regional Headquarters, Operating Units, and field personnel to ensure that NWS facilities comply with requirements of this procedure.
- b. NWSH will coordinate with NOAA SECO, as necessary, regarding compliance issues related to this procedure.

#### 13.4.4 Safety or Environmental/Safety Focal Point

- a. Will ensure that any responsibilities delegated to them by the Station Manager are implemented in accordance with the requirements of this procedure.
- b. Will investigate employee(s) concerns related to indoor air quality and shall ensure that deficiencies are remediated.

#### 13.4.5 Employees

Individual employees affected by this procedure are required to read, understand and comply with the requirements of this procedure and report unsafe or unhealthful conditions and practices to their supervisor or safety focal point.

<b>NOTE:</b> Reference NWS PD 50-11 for complete list of responsibilities <a href="http://www.weather.gov/directives/050/pd05011c.pdf">http://www.weather.gov/directives/050/pd05011c.pdf</a>
--

### 13.5 **References**

Incorporated references. The following list of references is incorporated as a whole or in part into this procedure. These references can provide additional explanation or guidance for the implementation of this procedure

- 13.5.1 American Conference of Governmental Industrial Hygienists, TLVs and BEIs, Threshold Limit Values for Chemical Substances and Physical Agents, Biological Exposure Indices.
- 13.5.2 American Society of Heating, Refrigerating, and Air Conditioning Engineers Standard 55, latest edition, “Thermal Environmental Conditions for Human Occupancy.”
- 13.5.3 American Society of Heating, Refrigerating, and Air Conditioning Engineers Standard 62, latest edition, “Ventilation for Acceptable Indoor Air Quality.”
- 13.5.4 U.S. Environmental Protection Agency, Building Air Quality: A Guide for Building Owners and Facility Managers.
- 13.5.5 U.S. Department of Labor, Occupational Safety and Health Administration, 29 CFR 1910, Subpart Z, “Toxic and Hazardous Substances.”

### 13.6 **Attachments**

None